

2012
PUEBLO COUNTY
APPLICATION FOR RIGHT-OF-WAY EXCAVATION PERMIT

PERMIT # 120282

The undersigned applicant being familiar with all of the requirements of Pueblo County Resolution No. 86-283 dated December 16, 1986, does hereby agree to perform all work in compliance with the regulations and specifications as set forth in accordance with said resolution and to adhere to requirements herein after specified:
24 Hour Notice Required Before Commencing Field Work

APPLICANT:

Application Fee: \$ 25.00*

Company: Colorado Springs Utilities

Address: 121 S. Tejon St, P.O. Box 1103,
Mail Code 930
Colorado Springs, CO 80947-0930

Allison Mosser

Your Name (Print)

Phone/Fax: (719) 668-8667 / (719) 668-8734

Begin Date: July 18, 2012

Completion Date: Sept 21, 2012

Project No: SDS RWP S2 Work Package

Resurfacing Contractor

Project Location: See Attached List

Street Address

Road Surface

Length

3
Cuts

3
Crossings

(Applicant Must Submit Sketch Of The Proposed Work Area)

The location of the project in relation to the roadway will be: (check all applicable)

Traffic Lane(s) ☒

Shoulder ☒

Drainage Ditch ☒

Right-Of-Way ☒

This work will consist of:

For the purpose of: Irrigation Sleeves

Cutting Road Surface ☒
Boring Under Road ☐
R.O.W. Excavation ☒
Setting a Pole ☐

Installing ☒
Repairing ☐
Removing ☐
Retiring ☐

MUTCD Traffic Control Plan By: CH2M Hill Engineers

T.C.P. No: CO PE #40108

Applicant or Representative Signature: Allison Mosser

THIS SECTION TO BE COMPLETED BY PUEBLO COUNTY REPRESENTATIVE

☒ Additional Requirements: Overlay ☐ Striping ☐ Compaction Test(s) ☒

Other DENSITY TESTING REQUIRED ON ALL ROAD CROSSINGS PER COUNTY STANDARD.

Street opening shall not exceed the length which will be backfilled before the end of the work day. You will be allowed to keep open a 3' x 5' pit until the next working day to facilitate the continuance of work only if the pit is protected by the required traffic control devices.

Temporary or permanent repairs (resurfacing) shall be completed no later than 24 hours ☐ or _____ days from the time /date of backfilling.

Completion /Warranty Date _____

Warranty Inspection Date _____

Accepted July 19, 2012

Denied _____, 2011

Reason For Denial _____

Pueblo County Representative: DAVID BENBOW (Not Valid Without Signature)

* INCLUDES ONE INSPECTION VISIT. INSPECTION FEE IS RATED AT \$22.26/HR. *

**PUEBLO COUNTY APPLICATION FOR RIGHT-OF-WAY EXCAVATION PERMIT
(SDS Irrigation Line Sleeve Installation – S2 Work Package)**

Right-of-Way Excavation Points

(Along the S2 pipeline alignment through Pueblo West, between East Sandusky Drive and North Blackstone Drive)

- 1) East Sandusky Drive (Gravel), approximately 550 feet east of intersection with North Thorpe Drive
- 2) East Kirkwood Drive (Gravel), approximately 550 feet east-southeast of intersection with North Thorpe Drive
- 3) North Blackstone Drive (Gravel), approximately 325 feet west of intersection with North Bat Masterson Lane